

Example Customer
 Hatchwood Place
 Farnham Road
 Odiham
 Hampshire RG29 1AB
 UK

Registration/Name §: .
 Customer Code: **BBB**
 Customer Reference §: .
 Completed Date: **13-Jul-15**

Description §:	<u>FUEL SAMPLE</u>	Sample Date §:	23-Dec-14	ADVANCED	
Laboratory Report Ref:	<u>FL12749</u>	Receipt Date:	29-Dec-14		
Unique Code:	<u>BBB.0001</u>	Incubation Date:	31-Dec-14		
Ticket Number:	<u>31121</u>	Analysis Date:	13-Jul-15		
Appearance	<u>Flash (M001)</u>	<u>Water (M017/23/26)</u>	<u>Hormoconis Resinae (M012 (NA))</u>	<u>Aerobic Bacteria (M012 (NA))</u>	
Clear (visual)	+60 (deg C)	<0.002 (% wt)	Positive	Positive	
<u>CFU (M012 (NA))</u>	<u>Density at 15°C (M011)</u>	<u>Sulphur (M015)</u>			
9500 (CFU/L approx)	0.8300 (kg/l)	0.057 (% wt)			
<p>Comment</p> <p>No debris present. No visible water present. CFU has been tested in accordance with in-house method based on IP385. Moderate microbiological contamination detected. Bacterial contamination approx. 2660 CFU/litre. Hormoconis resinae approx. 6840 CFU/litre.</p>					